City of Santa Fe, New Mexico

Attachment A-2

Table of Technical Corrections

- Traffic
- Landscape
- ADA
- MPO

Attachment A -2

	TABLE OF TECHNICAL CORRECTIONS	Department	To be completed by:
1	Should the rezone be approved, an "Initial Traffic Assessment" to consider the proposed development's traffic impacts to existing infrastructure will be required as part of the development plan approval process.	Traffic	At Dev. Plan / Subdivision Plat Application Submittal
2	City of Santa Fe Building Code, Chapter 23-3.2 states that before commencement of any new construction, it is mandatory for the owner to obtain approval from the public works department for any driveway curb cut or sidewalk crossing. This approval must be issued **before** a building permit for such new construction is approved.	Traffic	At Dev. Plan / Subdivision Plat Application Submittal
3	No comments	Landscape	
4	Sidewalks must be added to the PROW of Siringo Lane.	ADA	At Dev. Plan / Subdivision Plat Application Submittal
5	Sidewalks on Rancho Siringo Road must be repaired. All cracked, loose, or broken sections must be removed and replaced.	ADA	At Dev. Plan / Subdivision Plat Application Submittal
6	The Fire Hydrant in the sidewalk on Rancho Siringo Road must be removed from the sidewalk, and placed behind the sidewalk.	ADA	At Dev. Plan / Subdivision Plat Application Submittal
7	Drive entrances must comply with NMDOT series 608.	ADA	At Dev. Plan / Subdivision Plat Application Submittal
8	No comments	MPO	